

BACTERIOLOGICAL ANALYSIS - PUBLIC WATER SYSTEM

Laboratory ID #: 37501 County: CARTERET
Water System ID #: 04-16-191
Name of System: BIG RIDGE MHP
Sample Type: 5 (1 = Routine; 2 = Repeat; 3 = Replacement; 4 = Plan Approval; 5 = Other)
Collected on: DATE: 02/14/18 TIME: 10:27 AM
Location where collected: ENTRY
Location Type: (1 = Entry Tap; 2 = General Tap; 3 = End Tap; 4 = Source/Intakes; 5 = Other)
Location Code: _____ Collected By: Josh Pack

FOR REPEAT SAMPLE:

FOR REPLACEMENT SAMPLE:

Previous Positive Location Code: _____
Positive Collection Date: _____
Time: _____
Proximity:
(1 = Same; 2 = Upstream; 3 = Downstream)

Original Sample Type:
(1=Routine; 2=Repeat; 3=Plan Approval; 4=Other)
Original Collection Date: _____
Time _____

Mail Results To: **WILMINGTON REGIONAL OFFICE PWSS**
127 CARDINAL DRIVE EXTENSION
WILMINGTON, NC 28405
Telephone No. **9107967215**
EIN #: **566000372Q** COURIER #: **04-16-33**

Type of Supply: Community NTNC
 Non-Community Private

Type of Treatment: Chlorinated
 Non-Chlorinated
Free Chlorine Residual: 0.02 mg/l
Total Chlorine Residual: 0.00 mg/l

RESULTS

INVALID CODES

CONTAMINANT	METHOD	PRESENT	ABSENT	INVALID
Total Coliform	<u>9223B</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Fecal/E. Coli	<u>9223B</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Heterotrophic P.C.	_____	_____	_____ /ml	
(number)				

- 1) Confluent Growth/No Coliform Found
- 2) TNTC/No Coliform Found
- 3) Turbid Culture/No Coliform Found
- 4) Over 30 Hours Old
- 5) Improper Sample or Analysis

Repeat Samples Required

Replacement Samples Required

Date Analysis Begun: 02/15/18
Date Analysis Completed: 02/16/18
Laboratory Log #: _____

Time Analysis Begun: 09:00 AM
Time Analysis Completed: 09:00 AM
Certified By: Susan Beasley

COMMENTS: Special / Non-compliance (SP), Water Source: GW, Disinfectant Used: Bleach

