

BACTERIOLOGICAL ANALYSIS - PUBLIC WATER SYSTEM

Laboratory ID #: 37501 County: MOORE
Water System ID #: 03-63-621
Name of System: ST PETERS CHURCH OF GOD
Sample Type: 5 (1 = Routine; 2 = Repeat; 3 = Replacement; 4 = Plan Approval; 5 = Other)
Collected on: DATE: 06/19/17 TIME: 13:30 PM
Location where collected: AT WELL TAP
Location Type: (1 = Entry Tap; 2 = General Tap; 3 = End Tap; 4 = Source/Intakes; 5 = Other)
Location Code: E01 Collected By: Mike Lewis

FOR REPEAT SAMPLE:

Previous Positive Location Code: _____
Positive Collection Date: _____
Time: _____
Proximity:
(1 = Same; 2 = Upstream; 3 = Downstream)

FOR REPLACEMENT SAMPLE:

Original Sample Type:
(1=Routine; 2=Repeat; 3=Plan Approval; 4=Other)
Original Collection Date: _____
Time: _____

Mail Results To: **FAYETTEVILLE REGIONAL OFFICE PWSS**
225 GREEN ST STE 714
FAYETTEVILLE, NC 28301
Telephone No.
EIN #: 562033116M **COURIER #: 14-56-48**

Type of Supply: Community NTNC
 Non-Community Private

Type of Treatment: Chlorinated
 Non-Chlorinated
Free Chlorine Residual: _____ 0 mg/l
Total Chlorine Residual: _____ 0 mg/l

RESULTS

CONTAMINANT	METHOD	PRESENT	ABSENT	INVALID
Total Coliform	<u>9223B</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Fecal/E. Coli	<u>9223B</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Heterotrophic P.C.	_____	_____	_____ /ml	
		(number)		

INVALID CODES

- 1) Confluent Growth/No Coliform Found
- 2) TNTC/No Coliform Found
- 3) Turbid Culture/No Coliform Found
- 4) Over 30 Hours Old
- 5) Improper Sample or Analysis

Repeat Samples Required

Replacement Samples Required

Date Analysis Begun: 06/20/17
Date Analysis Completed: 06/21/17
Laboratory Log #: _____

Time Analysis Begun: 09:00 AM
Time Analysis Completed: 09:40 AM
Certified By: Susan Beasley

COMMENTS: Special / Non-compliance (SP), System Type: NC, Water Source: GW,
Disinfectant Used: None

