

BACTERIOLOGICAL ANALYSIS - PUBLIC WATER SYSTEM

Laboratory ID #: 37501 County: Guilford
Water System ID #: 02-41-710
Name of System: Cornerstone Bapt Ch
Sample Type: 5 (1 = Routine; 2 = Repeat; 3 = Replacement; 4 = Plan Approval; 5 = Other)
Collected on: DATE: 08/27/12 TIME: 11:00 AM
Location where collected: _____
Location Type: (1 = Entry Tap; 2 = General Tap; 3 = End Tap; 4 = Source/Intakes; 5 = Other)
Location Code: _____ Collected By: Blair Murray

FOR REPEAT SAMPLE:

FOR REPLACEMENT SAMPLE:

Previous Positive Location Code: _____
Positive Collection Date: _____
Time: _____
Proximity: (1 = Same; 2 = Upstream; 3 = Downstream)

Original Sample Type:
(1=Routine; 2=Repeat; 3=Plan Approval; 4=Other)
Original Collection Date: _____
Time: _____

Mail Results To: **WINSTON SALEM REGIONAL OFFICE PWSS**
WINSTON SALEM, NC 27107-2241
Telephone No. 336-771-5000
EIN #: 56 6000372 XX COURIER #: 13-15-01

Type of Supply: Community NTNC
 Non-Community Private

Type of Treatment: Chlorinated
 Non-Chlorinated
Free Chlorine Residual: _____
Total Chlorine Residual: _____

RESULTS

INVALID CODES

| CONTAMINANT | METHOD | PRESENT | ABSENT | INVALID |
|--------------------|--------------|-------------------------------------|-------------------------------------|--------------------------|
| Total Coliform | <u>9223B</u> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Fecal/E. Coli | <u>9223B</u> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Heterotrophic P.C. | _____ | _____/ml | | |
| (number) | | | | |

- 1) Confluent Growth/No Coliform Found
- 2) TNTC/No Coliform Found
- 3) Turbid Culture/No Coliform Found
- 4) Over 30 Hours Old
- 5) Improper Sample or Analysis

Repeat Samples Required

Replacement Samples Required

Date Analysis Begun: 08/28/12
Date Analysis Completed: 08/29/12
Laboratory Log #: 39262

Time Analysis Begun: 08:25 AM
Time Analysis Completed: 08:50 AM
Certified By: Susan Beasley

COMMENTS: Special/Non-compliance (SP), Water Source: Ground Water, Sample
Point: W01

