

BACTERIOLOGICAL ANALYSIS - PUBLIC WATER SYSTEM

Laboratory ID #: 37501 County: WILKES
Water System ID #: 01-97-538
Name of System: STONE MT. STATE PARK
Sample Type: 5 (1 = Routine; 2 = Repeat; 3 = Replacement; 4 = Plan Approval; 5 = Other)
Collected on: DATE: 11/30/15 TIME: 10:15 AM
Location where collected: KITCHEN SINK OFFICE
Location Type: (1 = Entry Tap; 2 = General Tap; 3 = End Tap; 4 = Source/Intakes; 5 = Other)
Location Code: KS1 Collected By: BLair Murray

FOR REPEAT SAMPLE:

FOR REPLACEMENT SAMPLE:

Previous Positive Location Code: _____
Positive Collection Date: _____
Time: _____
Proximity: (1 = Same; 2 = Upstream; 3 = Downstream)

Original Sample Type:
(1=Routine; 2=Repeat; 3=Plan Approval; 4=Other)
Original Collection Date: _____
Time _____

Mail Results To: **WINSTON SALEM REGIONAL OFFICE PWSS**
WINSTON SALEM, NC 27107-2241
Telephone No. **336-771-5000**
EIN #: **56 6000372 XX** COURIER #: **13-15-01**

Type of Supply: Community NTNC
 Non-Community Private

Type of Treatment: Chlorinated
 Non-Chlorinated
Free Chlorine Residual: _____
Total Chlorine Residual: _____

RESULTS

INVALID CODES

CONTAMINANT	METHOD	PRESENT	ABSENT	INVALID
Total Coliform	<u>9223B</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Fecal/E. Coli	<u>9223B</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Heterotrophic P.C.	_____	_____	_____ /ml	_____

(number)

- 1) Confluent Growth/No Coliform Found
- 2) TNTC/No Coliform Found
- 3) Turbid Culture/No Coliform Found
- 4) Over 30 Hours Old
- 5) Improper Sample or Analysis

Repeat Samples Required Replacement Samples Required

Date Analysis Begun: 12/01/15 Time Analysis Begun: 08:45 AM
Date Analysis Completed: 12/02/15 Time Analysis Completed: 12:10 PM
Laboratory Log #: _____ Certified By: Susan Beasley

COMMENTS: Special/Non-compliance (SP), System Type: TNC, Water Source: GW

