



North Carolina State Laboratory of Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

**FINAL REPORT**

Report to: Doug Whitmire

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS  
450 WEST HANES MILL RD STE 300  
WINSTON SALEM, NC 27105

Gibsonville Shell  
Location: Kitchen sink, Code: KS1  
System Type: TNC, Water Source: GW

EIN: 566000372X

Delivery: NC Courier

StarLiMS ID: **ES180712-0047**

Date Collected: 07/11/2018

Time Collected: 12:44

Date Received: 07/12/2018

Time Received: 08:29

Susan Beasley

Sample Source:

Sampling Point:

Sample Type:

GPS No.

Treatment:

Well Permit No.

Comment:

**PWS - Colilert Profile**

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			07/13/2018
E. coli	Absent			07/13/2018

Report Date: 07/16/2018

Reported By: Susan Beasley

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.