



North Carolina State Laboratory of Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

FINAL REPORT

Report to: MIKE LEWIS

Name of System:

FAYETTEVILLE REGIONAL OFFICE PWSS  
225 GREEN ST STE 714  
FAYETTEVILLE, NC 28301

McDonalds Chapel Presbyterian

EIN: 562033116M

Delivery: NC Courier

MOORE County

StarLiMS ID: **ES180807-0064**      Date Collected: 08/06/2018      Time Collected: 11:10      By: Mike Lewis  
Date Received: 08/07/2018      Time Received: 08:21      By: Susan Beasley  
Water System ID: 03-63-480      System Type: NC      Water Source: Ground Water  
Facility ID: D01      Sample Type: Special/Non-Compliance  
Sample Location: Kitchen sink      Location Type:      Location Code: K01  
Disinfectant Used:      Free Chlorine: 0 mg/L      Total Chlorine: 0 mg/L

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			08/08/2018
E. coli	Absent			08/08/2018

Report Date: 08/08/2018

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.