



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: T OVERBY

Name of System:

FAYETTEVILLE REGIONAL OFFICE PWSS
225 GREEN ST STE 714
Fayetteville, NC 28301

Harnett Co DPU

Lillington, NC

EIN: 562033116M

Delivery: NC Courier

Harnett County

StarLiMS ID: ES180905-0114	Date Collected: 09/04/2018	Time Collected: 10:35	By: T Overby
	Date Received: 09/05/2018	Time Received: 12:07	By: Angela Heybroek
Water System ID: 03-43-045	System Type: C	Water Source: Other	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location: 1029 Collins Rd	Location Type: 5	Location Code:	
Disinfectant Used:	Free Chlorine: 3.8 mg/L	Total Chlorine:	

Comments: Type of Treatment: Chlorinated

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			09/05/2018
E. coli	Absent			09/05/2018

Report Date: 09/07/2018

Reported By: **Susan Beasley**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.