



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Walker Keel

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
450 WEST HANES MILL RD STE 300
Winston Salem, NC 27105

Valley View S/D

EIN: 566000372X

Delivery: NC Courier

Watauga County

StarLiMS ID: **ES180920-0037**

Date Collected: 09/19/2018

Time Collected: 11:30 By: Walker Keel

Date Received: 09/20/2018

Time Received: 08:21 By: Angela Heybroek

Water System ID: 01-95-162

System Type: C

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Spigot

Location Type:

Location Code: 001

Disinfectant Used:

Free Chlorine: 0.8 mg/L

Total Chlorine:

Comments: Disinfectant Used: Chlorine

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			09/20/2018
E. coli	Absent			09/20/2018

Report Date: 09/21/2018

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.