



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to:** Blair Murray

**Name of System:**

**WINSTON SALEM REGIONAL OFFICE PWSS**  
 450 WEST HANES MILL RD STE 300  
 Winston Salem, NC 27105

**Reverence Farms Cafe'**

**EIN:** 566000372X

**Delivery:** NC Courier

**Alamance County**

StarLiMS ID: **ES181129-0061**

Date Collected: 11/28/2018

Time Collected: 13:05 By: Blair Murray

Date Received: 11/29/2018

Time Received: 08:32 By: Susan Beasley

Water System ID: 00-00-000

System Type: NTNC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Kitchen

Location Type:

Location Code: E01

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments:

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			11/29/2018
E. coli	Absent			11/29/2018

**Report Date:** 12/04/2018

**Reported By:** Susan Beasley

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.