



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Tammy Taylor

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
 450 WEST HANES MILL RD STE 300
 Winston Salem, NC 27105

Brookdale S/D
 202 Springview Lane
 Mount Airy, NC 27030

EIN: 566000372X

Delivery: NC Courier

Surry County

StarLiMS ID: ES190306-0041	Date Collected: 03/05/2019	Time Collected: 10:45	By: Tammy Taylor
	Date Received: 03/06/2019	Time Received: 09:01	By: Angela Heybroek
Water System ID: 02-86-158	System Type: C	Water Source: Ground Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location: Outside tap	Location Type:	Location Code: 010	
Disinfectant Used:	Free Chlorine: 1.15 mg/L	Total Chlorine:	

Comments: Disinfectant Used: Chlorine.

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			03/06/2019
E. coli	Absent			03/06/2019

Report Date: 03/08/2019

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.