



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Mike Painter

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
450 WEST HANES MILL RD STE 300
Winston Salem, NC 27105

Autumn Forest MHP

EIN: 566000372X

Delivery: NC Courier

Guilford County

StarLiMS ID: **ES190314-0001**

Date Collected: 03/13/2019

Time Collected: 10:23 By: Mike Painter

Date Received: 03/14/2019

Time Received: 07:30 By: Denise Richardson

Water System ID: 02-41-103

System Type: C

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Lot 141

Location Type:

Location Code: 141

Disinfectant Used:

Free Chlorine: 0.72 mg/L

Total Chlorine:

Comments: Disinfectant Used: Chlorine

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			03/14/2019
E. coli	Absent			03/14/2019

Report Date: 03/18/2019

Reported By: **Susan Beasley**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.