



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Mike Painter

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
450 WEST HANES MILL RD STE 300
Winston Salem, NC 27105

Cedar Park MHP

EIN: 566000372X

Delivery: NC Courier

Guilford County

StarLiMS ID: ES190328-0041	Date Collected: 03/27/2019	Time Collected: 15:00	By: Mike Painter
	Date Received: 03/28/2019	Time Received: 08:38	By: Angela Heybroek
Water System ID: 02-41-105	System Type: C	Water Source: Ground Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location: Outside tap	Location Type: Lot 26	Location Code: 003	
Disinfectant Used:	Free Chlorine: 0.6 mg/L	Total Chlorine:	

Comments: Disinfectant Used: Chlorine

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			03/28/2019
E. coli	Absent			03/28/2019

Report Date: 03/29/2019

Reported By: **Susan Beasley**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.