



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: ALLEN BAKER

Name of System:

WILMINGTON REGIONAL OFFICE PWSS
127 CARDINAL DRIVE EXTENSION
Wilmington, NC 28405

WQ Goodman LLC

EIN: 566000372Q

Delivery: NC Courier

New Hanover County

StarLiMS ID: ES190516-0059	Date Collected: 05/15/2019	Time Collected: 14:03	By: Allen Baker
	Date Received: 05/16/2019	Time Received: 08:11	By: Tyler Best
Water System ID: 70-65-058	System Type: NTNC	Water Source: Ground Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location: Wellhead faucet	Location Type:	Location Code:	
Disinfectant Used:	Free Chlorine:	Total Chlorine:	

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			05/16/2019
E. coli	Absent			05/16/2019

Report Date: 05/20/2019

Reported By: **Susan Beasley**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.