



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Tim Appelboom

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
 450 WEST HANES MILL RD STE 300
 Winston Salem, NC 27105

Jacob's Creek Nurs & Rehab Ctr
 1721 Bald Hill Loop
 Madison, NC 27025

EIN: 566000372X

Delivery: NC Courier

Rockingham County

StarLiMS ID: ES190605-0047	Date Collected: 06/04/2019	Time Collected: 13:05	By: Tim Appelboom
	Date Received: 06/05/2019	Time Received: 08:13	By: Tyler Best
Water System ID: 02-79-410	System Type: C	Water Source: Ground Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location: Laundry sink	Location Type:	Location Code: 011	
Disinfectant Used:	Free Chlorine: 1.52 mg/L	Total Chlorine:	
Comments: Disinfectant used: Sodium hypochlorite			

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			06/05/2019
E. coli	Absent			06/05/2019

Report Date: 06/06/2019

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.