



North Carolina State Laboratory of Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

FINAL REPORT

Report to: ALLEN BAKER

Name of System:

WILMINGTON REGIONAL OFFICE PWSS  
127 CARDINAL DRIVE EXTENSION  
Wilmington, NC 28405

New Britton Missionary Baptist Ch

EIN: 566000372Q

Delivery: NC Courier

Brunswick County

StarLiMS ID: ES190822-0045

Date Collected: 08/21/2019

Time Collected: 10:25 By: Allen Baker

Date Received: 08/22/2019

Time Received: 08:13 By: Angela Heybroek

Water System ID: 70-10-009

System Type: NTNC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: BBQ kitchen faucet

Location Type:

Location Code:

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			08/22/2019
E. coli	Absent			08/22/2019

Report Date: 08/23/2019

Reported By: KPLEMMONS

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.