



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Blair Murray

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
 450 WEST HANES MILL RD STE 300
 Winston Salem, NC 27105

Level Cross Enrichment Center

EIN: 566000372X

Delivery: NC Courier

Randolph County

StarLiMS ID: **ES191217-0039**

Date Collected: 12/16/2019

Time Collected: 09:50 By: Blair Murray

Date Received: 12/17/2019

Time Received: 07:57 By: Angela Heybroek

Water System ID: 30-76-003

System Type: NTNC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Kitchen tap

Location Type:

Location Code: E01

Disinfectant Used:

Free Chlorine:

Total Chlorine: 2.2 mg/L

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			12/17/2019
E. coli	Absent			12/17/2019

Report Date: 12/18/2019

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.