



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Seth Titley

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
450 WEST HANES MILL RD STE 300
Winston Salem, NC 27105

Deep Creek Baptist Church

EIN: 566000372X

Delivery: Hand Delivered

Yadkin County

StarLiMS ID: **ES200109-0146**

Date Collected: 01/08/2020

Time Collected: 13:05 By: Seth Titley

Date Received: 01/09/2020

Time Received: 11:24 By: Angela Heybroek

Water System ID: 0299-510

System Type: NTNC

Water Source: Ground Water

Facility ID: W02

Sample Type: Special/Non-Compliance

Sample Location: Well head

Location Type:

Location Code:

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			01/09/2020
E. coli	Absent			01/09/2020

Report Date: 01/10/2020

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.