



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
 http://slph.ncpublichealth.com  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to: MIKE LEWIS**

**Name of System:**

**FAYETTEVILLE REGIONAL OFFICE PWSS**  
**225 GREEN ST STE 714**  
**Fayetteville, NC 28301**

**Hair's Freewill Holiness Church**

**EIN: 562033116M**

**Delivery: NC Courier**

**Cumberland County**

StarLiMS ID: **ES200114-0038**

Date Collected: 01/13/2020

Time Collected: 09:40 By: Mike Lewis

Date Received: 01/14/2020

Time Received: 07:59 By: Denise Richardson

Water System ID: 03-26-483

System Type: NC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: At well

Location Type:

Location Code: E01

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments:

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			01/15/2020
E. coli	Absent			01/15/2020

**Report Date:** 01/15/2020

**Reported By:** **KPLEMMONS**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.