



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
 http://slph.ncpublichealth.com  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to: MIKE LEWIS**

**Name of System:**

**FAYETTEVILLE REGIONAL OFFICE PWSS**  
 225 GREEN ST STE 714  
 Fayetteville, NC 28301

**Dollar General - Alderman Road**

**EIN: 562033116M**

**Delivery: NC Courier**

**Cumberland County**

StarLiMS ID: **ES200226-0048**

Date Collected: 02/25/2020

Time Collected: 10:00 By: Mike Lewis

Date Received: 02/26/2020

Time Received: 08:11 By: Tyler Best

Water System ID: 00-00-000

System Type: NC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Well sample tap

Location Type:

Location Code: E01

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments: Potential new water system

**PWS - Colilert Profile**

**Method: SM 9223B**

| Analyte        | Test Result | Unit | Conclusion | Date Tested |
|----------------|-------------|------|------------|-------------|
| Total Coliform | Absent      |      |            | 02/26/2020  |
| E. coli        | Absent      |      |            | 02/26/2020  |

**Report Date:** 02/27/2020

**Reported By:** **KPLEMMONS**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.