



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to: Janet Mills**

**Name of System:**

**MOORESVILLE REGIONAL OFFICE PWSS**  
**610 EAST CENTER AVENUE**  
**Mooreville, NC 28115**

**United Christian Fellowship**  
**1077 Twin Chapel Road**

**EIN: 566000037AA**

**Delivery: NC Courier**

**Rowan County**

StarLiMS ID: <b>ES201208-0038</b>	Date Collected: 12/07/2020	Time Collected: 14:15	By: Janet Mills
	Date Received: 12/08/2020	Time Received: 07:47	By: Denise Richardson
Water System ID: 20-80-008	System Type: NTNC	Water Source: Ground Water	
Facility ID: D01		Sample Type: Special/Non-Compliance	
Sample Location: Kitchen Sink 1077 Tw	Location Type:	Location Code: 300	
Disinfectant Used:	Free Chlorine:	Total Chlorine:	

Comments:

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			12/08/2020
E. coli	Absent			12/08/2020

**Report Date:** 12/09/2020

**Reported By:** **KPLEMMONS**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.