



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Tim Appelboom

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
 450 WEST HANES MILL RD STE 300
 Winston Salem, NC 27105

Lake Reidsville Rec Park
 630 Water Works Rd
 Reidsville, NC 27320

EIN: 566000372X

Delivery: NC Courier

Rockingham County

StarLiMS ID: ES210204-0044	Date Collected: 02/03/2021	Time Collected: 09:12	By: Tim Appelboom
	Date Received: 02/04/2021	Time Received: 08:36	By: Angela Heybroek
Water System ID: 02-79-158	System Type: NC	Water Source: Ground Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location: Shelter 5	Location Type:	Location Code: A13	
Disinfectant Used:	Free Chlorine: 2.10 mg/L	Total Chlorine:	

Comments: Disinfectant Used: Sodium hypochlorite.

PWS - Colisure Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			02/04/2021
E. coli	Absent			02/04/2021

Report Date: 02/05/2021

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.